

## SECTION 03311

## SEAL SLABS

## PART 1 GENERAL

## 1.01 SECTION INCLUDES

- A. Concrete seal slabs.

## 1.02 PRICES

- A. Measurement for seal slabs is incidental to pay item.

## 1.03 SUBMITTALS

- A. Conform to all provisions and sections of these specifications.
- B. Submit design mix and test data, prepared by a certified independent testing laboratory employed and paid by the Contractor, for each type and strength of concrete in the project. Include manufacturer's technical information for each type of admixture proposed for use on the project.

## PART 2 PRODUCTS

## 2.01 MATERIALS

- A. Concrete: Class B concrete with a minimum compressive strength at 28 days of 1500 psi, conforming to Section 03305 - Concrete for Utility Construction, or 03310 - Structural Concrete.

## PART 3 EXECUTION

## 3.01 PLACEMENT OF SEAL SLABS

- A. Place seal slabs at locations indicated on Drawings or as directed by the Owner's Representative.
- B. Excavate trench or other excavation to depth required for pipe or other installation, plus depth of seal slab. Do not over-excavate.
- C. Place seal slabs within 4 hours of excavation to final grade.

END OF SECTION